



# *The Ontario Water Resources Act* **WATER WELL RECORD**

**Print only in spaces provided.**  
**Mark correct box with a checkmark, where applicable.**

11

3613547

Municipality 36003 Con. CON 05

County or District	Township/Borough/City/Town/Village	Con block tract survey, etc.	Lot	25-27
	North Crosby	5	3	
	Address	Date completed		48-53
	R.R.#2, Westport, KOG 1X0	4 day 07 month 95 year		

[illegible]

41		WATER RECORD				21	
Water found at – feet		Kind of water					
118	10-12	1	Fresh	3	Sulphur	14	
		2	Salty	4	Minerals		
15-18		5	Gas	6			
		1	Fresh	3	Sulphur	19	
		2	Salty	4	Minerals		
				5	Gas		
20-23		1	Fresh	3	Sulphur	26	
		2	Salty	4	Minerals		
				5	Gas		
24-26		1	Fresh	3	Sulphur	29	
		2	Salty	4	Minerals		
				5	Gas		
30-35		1	Fresh	3	Sulphur	34	
		2	Salty	4	Minerals		
				5	Gas		

5.1		32		43		CASING & OPEN HOLE RECORD	
Inside diam inches	Material	Wall thickness inches	Depth – feet				
			From	To			
6 1/4"	<input checked="" type="checkbox"/> Steel <input type="checkbox"/> Galvanized <input type="checkbox"/> Concrete <input type="checkbox"/> Open hole <input type="checkbox"/> Plastic	.188	0	22			
6"	<input type="checkbox"/> Steel <input type="checkbox"/> Galvanized <input type="checkbox"/> Concrete <input checked="" type="checkbox"/> Open hole <input type="checkbox"/> Plastic		22	125			
	<input type="checkbox"/> Steel <input type="checkbox"/> Galvanized <input type="checkbox"/> Concrete <input type="checkbox"/> Open hole <input type="checkbox"/> Plastic						

SCREEN	Sizes of opening (Slot No.)	Diameter	Length
		inches	feet
	Material and type	Depth at top of screen	
		feet	

61	<b>PLUGGING &amp; SEALING RECORD</b>		
<input type="checkbox"/> Annular space		<input type="checkbox"/> Abandonment	
Depth set at - feet		Material and type (Cement grout, bentonite, etc.)	
From	To		
10-13	14-17	cement grout	
4	22		
18-21	22-25		
26-29	30-33	34	

PUMPING TEST	Pumping test method <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Bailer		Pumping rate 10 GPM		Duration of pumping 1 Hour    10 Mins	
	Static level	Water level end of pumping	Water levels during <input type="checkbox"/> Pumping <input type="checkbox"/> Recovery			
			15 minutes	30 minutes	45 minutes	60 minutes
	6 feet	120 feet	feet	feet	feet	feet
	If flowing give rate GPM		Pump intake set at 115 feet		Water at end of test <input checked="" type="checkbox"/> Clear <input type="checkbox"/> Cloudy	
Recommended pump type <input type="checkbox"/> Shallow <input checked="" type="checkbox"/> Deep		Recommended pump setting 115 feet		Recommended pump rate 10 GPM		

<b>FINAL STATUS OF WELL</b>		
<input checked="" type="checkbox"/> Water supply	<input type="checkbox"/> Abandoned, insufficient supply	<input type="checkbox"/> Unfinished
<input type="checkbox"/> Observation well	<input type="checkbox"/> Abandoned, poor quality	<input type="checkbox"/> Replacement well
<input type="checkbox"/> Test hole	<input type="checkbox"/> Abandoned (Other)	
<input type="checkbox"/> Recharge well	<input type="checkbox"/> Dewatering	

---

<b>WATER USE</b>		
<input checked="" type="checkbox"/> Domestic	<input type="checkbox"/> Commercial	<input type="checkbox"/> Not used
<input type="checkbox"/> Stock	<input type="checkbox"/> Municipal	<input type="checkbox"/> Other .....
<input type="checkbox"/> Irrigation	<input type="checkbox"/> Public supply	
<input type="checkbox"/> Industrial	<input type="checkbox"/> Cooling & air conditioning	

---

<b>METHOD OF CONSTRUCTION</b>		
<input type="checkbox"/> Cable tool	<input checked="" type="checkbox"/> Air percussion	<input type="checkbox"/> Driving
<input type="checkbox"/> Rotary (conventional)	<input type="checkbox"/> Boring	<input type="checkbox"/> Digging
<input type="checkbox"/> Rotary (reverse)	<input type="checkbox"/> Diamond	<input type="checkbox"/> Other .....
<input type="checkbox"/> Rotary (air)	<input type="checkbox"/> Jetting	

**LOCATION OF WELL**

In diagram below show distances of well from road and lot line. Indicate north by arrow.

42


1 km.

1 km.

HUTCHINGS RD.

UPPER RIDEAU

153575

Name of Well Contractor	Well Contractor's Licence No.
J.R.Thompson	4905
Address	
R.R.#1, Westport, On. K0G 1X0	
Name of Well Technician	Well Technician's Licence No.
Donald Smith	T0328
Signature of Technician/Contractor	Submission date
	day 2 mo 8 yr 95

MINISTRY USE ONLY	Date Source	Contractor <b>4905</b>	Date received <b>SEP 22 1995</b>
	Date of payment	Remarks	