

WETT RECOMMENDED INSPECTION CHECKLIST

Requested by: [REDACTED]	Inspection location: ☒ Same as requested or:
Address: 169 Seapoint Lane Westport, ON	Address:
Postal code:	Postal code:
Phone no's: 613-273-9640	Phone no's:
Inspector's name: Ashley S.	WETT no.: 13020
Reason(s) for inspection: Insurance	
Level of inspection requested: ☒ Level 1 ☐ Level 2 ☐ Level 3	
Date of request:	Date of inspection: March 24/25

FACTORY-BUILT CHIMNEY

Chimney classification:	☒ ULC S629 (650C) ☐ ULC S694 (FB Type A)
	☐ ULC S610 (FB Fireplace Chimney) ☐ Unknown
Listing agency:	☐ ULC ☐ CSA ☒ WH(ITS) ☐ UL ☐ OTL
Manufacturer:	ICC ☐ Unknown
Installation manual available:	☒ No ☐ Yes
Installed by:	Date: ☒ Unknown Approx age: 10-15 yr
Total height: 22 ft Flue Size: 7"	☒ Inside installation ☐ Outside installation

Inspection Results: Indicate inspection results for each component. Code Compliance includes proper use of listed components. N/A = Not Applicable UTI = Unable To Inspect. An inspection can be expected to include some components marked UTI.

COMPONENT	CODE COMPLIANCE
1. Horizontal extension beyond inside wall surface	☒ N/A ☐ No ☐ Yes ☐ UTI
2. Wall radiation shield	☒ N/A ☐ No ☐ Yes ☐ UTI
3. Clean-out Tee and cap	☒ N/A ☐ No ☐ Yes ☐ UTI
4. Wall supports	☒ N/A ☐ No ☐ Yes ☐ UTI

Continued over page.

FACTORY-BUILT CHIMNEY, page 2

COMPONENT, continued	CODE COMPLIANCE, continued
5. Support spacing	☐ N/A ☐ No ☐ Yes ☒ UTI
6. Support above offset	☐ N/A ☐ No ☐ Yes ☒ UTI
7. Ceiling support	☒ N/A ☐ No ☐ Yes ☐ UTI
8. Firestops/radiation shields	☒ N/A ☐ No ☐ Yes ☐ UTI
9. Attic radiation shield	☒ N/A ☐ No ☐ Yes ☐ UTI
10. Enclosed through living space	☐ N/A ☐ No ☒ Yes ☐ UTI
11. Roof flashing	☐ N/A ☐ No ☒ Yes ☐ UTI
12. Roof Braces	☐ N/A ☐ No ☒ Yes ☐ UTI
13. Rain Cap	☐ No ☒ Yes ☐ UTI
14.	☐ No ☐ Yes ☐ UTI
OTHER CONSIDERATIONS	CODE COMPLIANCE
15. Height above roof surface: minimum 3' required	☐ No ☒ Yes
16. Height above any roof surface or structure within 10' 2' required	☐ No ☒ Yes
17. Chimney clearance to combustibles	☐ No ☒ Yes ☐ UTI
18. Areas of chimney enclosed or hidden ☐ No ☒ Yes <i>chase box</i>	
19. Attached appliance(s) <i>RSE</i>	Specify <i>Fire place</i>
Photos taken: ☐ No ☒ Yes	
Your file reference:	
Comments and Observations. All non-compliance ratings should be considered for comment. Attach additional page(s) if needed.	
This checklist contains <i>2</i> pages in total. The Inspection Report contains <i>7</i> pages in total.	
Inspector Signature: <i>[Signature]</i>	
Date: <i>03/24/25</i>	

WETT RECOMMENDED INSPECTION CHECKLIST

Requested by: [REDACTED]	Inspection location: ☒ Same as requested or:
Address: 169 Seapoint Lane Westport, ON	Address:
Postal code:	Postal code:
Phone no's: 613-273-9640	Phone no's:
Inspector's name: Ashley S.	WETT no.: 13020
Reason(s) for inspection: Insurance	
Level of inspection requested: ☒ Level 1 ☐ Level 2 ☐ Level 3	
Date of request:	Date of inspection: March 24/25

FACTORY BUILT FIREPLACE

Certification standard: ☒ ULC S610 ☐ EPA ☐ CSA B415 ☐ Unknown ☐ Uncertified			
Listing agency: ☒ ULC ☐ CSA ☐ WH(ITS) ☐ UL ☐ OTL			
Manufacturer: RSF	Serial number: 15251	Model: Delta	Flue size: 7"
Installation manual available: ☐ No ☐ Yes			
Venting system that is listed and connected to this fireplace:			
☒ ULC S610FB ☐ ULC S629FB		Model:	Manufacturer: ICC
☐ Masonry ☐ Masonry with stainless steel liner ☐ Other:			
System installed by:	Date:	☒ Unknown	Approx age: 10-15 yrs.
Appliance location: ☐ Basement ☒ Main floor ☐ Other (specify):			

Inspection Results: Indicate inspection results for each component. Code Compliance includes proper use of listed components. N/A = Not Applicable UTI = Unable To Inspect. An inspection can be expected to include some components marked UTI.

FACE CLEARANCES	ACTUAL(S)	CODE COMPLIANCE
1. Combustible mantle shelf		☒ N/A ☐ No ☐ Yes
2. Combustible side legs		☒ N/A ☐ No ☐ Yes
3. Combustible facing trim		☒ N/A ☐ No ☐ Yes

Continued over page

FACTORY BUILT FIREPLACE, page 2

FACE CLEARANCES	ACTUAL(S)	CODE COMPLIANCE
4. Non combustible facing		☐ N/A ☐ No ☒ Yes ☐ UTI
5. Side wall		☒ N/A ☐ No ☐ Yes
6. Hearth size/material		☐ N/A ☐ No ☒ Yes
7.		☐ No ☐ Yes ☐ UTI

OTHER CONSIDERATIONS	ACTUAL(S)	CODE COMPLIANCE
8. Outdoor combustion air Required? ☐ No ☒ Yes	☐ No ☒ Yes	☐ No ☒ Yes ☐ UTI
9. Remote gravity vent(s)	☒ No ☐ Yes	☐ No ☒ Yes ☐ UTI
10. Central heating kit	☒ No ☐ Yes	☐ No ☒ Yes ☐ UTI
11. Fireplace to chimney connection		☐ No ☒ Yes ☐ UTI
12. Clearances within enclosure		☐ N/A ☐ No ☐ Yes ☒ UTI
13.		☐ No ☐ Yes ☐ UTI
14.		☐ No ☐ Yes ☐ UTI
Photos taken: ☐ No ☒ Yes Your file reference:		

Comments and Observations. All non-compliance ratings should be considered for comment. Attach additional page(s) if needed.

This checklist contains 2 pages in total. The Inspection Report contains 7 pages in total.

Inspector Signature: 

Date: 03/24/25



WARNOCK HERSEY Listed Factory Built Fireplace



Model : Delta

Serial No.

WH- 15251

Report: 476-1074 (Jan 95)

Certified in Canada and the USA

Standards UL-127, ULC-S610, ULC-S627

Install and use only in accordance with the manufacturers installation and operating instructions. Do not obstruct combustion air inlet. Operate only with viewing door closed and latched. Open to feed fire only. For use with solid wood fuels only. Operate only with fire brick in place.

Unit top, back, sides, and bottom

0 in (0 mm) min without duct

Face of unit

28 in (1980 mm) min from floor with duct

Mantle top facing

No combustibles permitted

Adjacent sidewall

11 1/2 in (290 mm) min from top lou

11 in (275 mm) min from side of unit

Floor must be protected by a noncombustible material extending at least 16 in (405mm) to front and 8 in (205 mm) to sides of fireplace opening.

Components required for installation: Combustion air inlet assembly and minimum 5 in (125mm) diameter flexible duct. One of the following 8 in (205mm) Diameter listed chimney systems, compete with components as specified in the RSF installation instructions. Systems which are tested and listed to ULC-S629 standard: James A. Ryder model HT 5103, James A. Ryder model AC, Selkirk Metalbestos model SBII, Simonson DuraVent model Dura Plus (RSP), American Metal Products Co. model Ameri-Tech HS Guard, ICC Inc. model 2x6 HT.

Optional Components:

External Blower Assembly - Part No FDH85-N

Wall Mount Kit - Part No FDHC4

Wall Duct - Part No FDVD



RSF Energy Ltd.
2965 Tatlow Road, P.O. Box 3637
Smithers, B.C. Canada V0J 2N0

