



SOLID-FUEL BURNING EQUIPMENT COMPLIANCE REPORT



CLIENT: [REDACTED]	DATE OF INSPECTION: Oct 9/12
ADDRESS: 441 Maccomish Lane Westport, ON	PHONE: [REDACTED]
POSTAL CODE:	CELL NO.:

WOODSTOVE AND FLUE PIPE

APPLIANCE STANDARD: ☒ ULCS 627 ☐ EPA ☐ CSA B415 ☐ Unknown ☐ Uncertified

LISTING AGENCY: ☐ ULC ☐ CSA ☒ WH (ITS) ☐ UL ☐ OTL

MANUFACTURER: Pacific Energy SERIAL NO.: 236769

MODEL: TS FLUE SIZE: 6

INSTALLED BY: The Stove Store INSTALLATION MANUAL AVAILABLE: ☐ NO ☒ YES

INSTALLED IN: ☒ Residence ☐ Mobile Home ☐ Combustible Alcove ☐ Garage ☐ Other: _____

INSTALLED IN: ☐ Basement ☒ Main Floor ☐ Other: _____

Inspection Results: Indicate inspection results for each component. Code Compliance includes proper use of listed components.
An inspection can be expected to include some components marked UTI.
N/A = Not Applicable UTI = Unable To Inspect.

CLEARANCES	ACTUAL	REQ'D	CODE COMPLIANCE
Combustible Side Wall			☒ N/A ☐ NO ☐ YES
Combustible Rear Wall	5"	5"	☐ N/A ☐ NO ☒ YES
Combustible Corner			☒ N/A ☐ NO ☐ YES
Top/Ceiling Clearance	95"	82"	☒ N/A ☐ NO ☐ YES
Shielding			☒ N/A ☐ NO ☐ YES
Ember Pad Size	21"	18"	☐ N/A ☐ NO ☒ YES
Ember Pad Material	Tile		☐ N/A ☐ NO ☒ YES
Heat Protection: Floor	Tile		☐ N/A ☐ NO ☒ YES

Notes:

FLUE PIPE TYPE:	☐ Single ☒ Double	SIZE: 6"	
CLEARANCES	ACTUAL	REQ'D	CODE COMPLIANCE
Flue Pipe			☐ NO ☒ YES
Total Length	60"		☐ N/A ☐ NO ☒ YES
Elbows			☒ N/A ☐ NO ☐ YES
Fastening	screws		☐ N/A ☐ NO ☒ YES
Expansion Joint if Vertical			☐ N/A ☐ NO ☒ YES
Connection to Breech			☐ N/A ☐ NO ☒ YES
Connection to Chimney			☐ N/A ☐ NO ☒ YES

Notes:

OTHER CONSIDERATIONS	CODE COMPLIANCE
Alcove Approved	☐ NO ☐ YES ☒ N/A ☐ NO ☐ YES
Mobile Home Approved	☐ NO ☐ YES ☒ N/A ☐ NO ☐ YES
Outdoor Air Connection	☐ NO ☐ YES ☒ N/A ☐ NO ☐ YES
Required?	☐ NO ☐ YES ☒ N/A ☐ NO ☐ YES
Photos Taken	☐ NO ☒ YES

Notes: (Appliance condition, etc.)

INSPECTOR: Chad Belanger
SIGNATURE: [Signature]
WETT NO. 9353
DATE Oct 9/12



6 Beverly St., Box 1 Spencerville, ON K0E 1X0

P: 613-658-3101 F: 613-658-3282

thestovestore@ripnet.com www.thestovestore.net

UNIT NO.: _____

Inspection results are at time of inspection, and therefore may have been modified since.
Therefore, The Stove Store is in no way responsible after the date of inspection.