

APPLICATION NO.

51486-88

4, 5, 6 SEWAGE SYSTEMS

INSPECTION DETAILS

TIME
10¹⁵ AM
THE OWNERDATE
June 23/88WEATHER
Cloudy
THE INSTALLER
T. Munton

REPRESENTING

1. Work authorized by the Certificate of Approval has been satisfactorily completed and includes:
- a) Septic tank ~~holding tank~~ of working capacity of 600 Imp. Gals. constructed of steel ☐ concrete ☒ fibreglass ☐
on site ☐ or prefabricated ☒ to serve 2 (no. of bedrooms or units).


MAKE AND MODEL

IF PREFABRICATED TANK Anchor

- b) Leaching bed of total 62 lineal feet of 3 inch diameter distribution pipe of PVC
(type and product description e.g. manufacturer(s) and material of which pipe is made) laid
in 4 x 4 7m runs and fed by GRAVITY (gravity, siphon, pump). (Model)
- c) Proprietary Aerobic System: (Manufacturer)
- d) Other details LONG AREA 4.2 x 5.9m

2. Location

if located other than in (a) use space below for sketch and dimensions from permanent points of reference sufficient to facilitate future location of tank and leaching bed including orientation of pipe runs.



3. The following work remains to be completed:—

- ☒ Backfill System and Complete ☒ Finish Grading to Shed Run-off and Divert Water Around Leaching Bed
- ☒ Stabilize All Sloped Surfaces ☐ Other

USE PERMIT

Under Section 67 of the Environmental Protection Act, and subject to the provisions of the Act and Regulations a Permit is hereby issued to (Owner) ANNIE PALMER for the use and operation of the

Class 1, 2, 3, 4, 5, 6 sewage system constructed/installed/enlarged/extended/alterd pursuant to the Certificate of Approval issued under the above application number in accordance with the application and Certificate of Approval with any changes indicated above and located on Lot 5 Concession 1 Ward/Township/Municipality SHERBROOKE
Region/District/County LANARK Plan No. Sub-Lot No.

INSPECTED AND RECOMMENDED BY

PERMIT ISSUED BY

DATE ISSUED

DIRECTOR

June 24/88

Note: Section 64(a) of the Act provides that no change can be made to any building(s) or structure(s) in connection with which this sewage system is used, if the operation or effectiveness of the sewage system will or is likely to be affected by the change, unless a new Certificate of Approval is obtained.

Section 121 of the Act provides that an applicant for a permit may appeal a decision to refuse to issue a permit. Written notice of appeal must be forwarded to the Director (who refused to issue the permit) and to the Environmental Appeal Board, 2300 Yonge Street, P.O. Box 2382, Suite 1201, Toronto, Ontario M4P 1E4 within 15 days of receipt of a permit.

WARNING: UNDER NO CIRCUMSTANCES SHOULD A HOMEOWNER ENTER A SEPTIC TANK. NOXIOUS GASES WHICH ARE HEAVIER THAN AIR REMAIN IN THE TANK AFTER THE TOP IS REMOVED, AND HAVE CAUSED DEATH BOTH TO THE ORIGINAL VICTIM AND TO THOSE WHO ATTEMPT TO RESCUE HIM FROM THE TANK.

Martin's Excavation & Trucking



Westport, Ontario
K0G 1X0

Septic Systems installed & repaired
Backhoe, Bulldozer & Truck Rental

Phone
273-5799

In Account With



DESCRIPTION	AMOUNT
Installation of 600 gallon tank and filter bed	00.00
Invoice #18497	119.19
Less	13.56
	05.63
Invoice #16606	558.11
Less	444.10
	401
Invoice #18539	72.36
Less	51.69
	20.67
3 yard stone	50.00
Material Tax	
Pd by Annie By cheque	
269.31 also pd by Annie	
Paid in Full June 27/98	
Jung Martin Pd by Annie	
TOTAL	2690.31