

Address of Well Location (Street Number/Name) 388 Bolingbrooke Road, Maleny Township So. Sherbrooke Lot 11 Concession 4
 County/District/Municipality Seeds City/Town/Village Hustport Province Ontario Postal Code K0G 1X0
 UTM Coordinates Zone 18 Easting 330797 Northing 4961434 Municipal Plan and Sublot Number Part 12 Part 1 27R1966 L115 Block 26 P1 29.

Overburden and Bedrock Materials/Abandonment Sealing Record (see instructions on the back of this form)

General Colour	Most Common Material	Other Materials	General Description	Depth (m/ft)	
				From	To
	earth/sand			0'	2'
	grey/white granite			2'	30'
	white/gray granite			30'	70'
	white/gray/pink granite			70'	90'
	white/gray granite			90'	110'
	black/gray granite			110'	190'
	gray/white granite			190'	220'

PT NE 1/2 Lot 12 Cons 5 Part 4 27R2469 South Sherbrooke Twp.

Annular Space

Depth Set at (m/ft)	Type of Sealant Used (Material and Type)	Volume Placed (m³/ft³)
From	To	
0	2 Bags Cement	0.044
	2 Bags quick grout	0.044
	Heavily driven shoe	

Results of Well Yield Testing

Time (min)	Draw Down (m/ft)		Time (min)	Recovery (m/ft)	
	Water Level (m/ft)	Static Level (m/ft)		Water Level (m/ft)	Static Level (m/ft)
1	21.3'	1	57.1'		
2	22.8'	2	53.9'		
3	23.8'	3	50.8'		
4	24.5'	4	47.7'		
5	24.9'	5	44.6'		
10	27.6'	10	29.7'		
15	30.6'	15	20.8'		
20	34.4'	20	20.3'		
25	37.8'	25	20.3'		
30	41.2'	30	20.3'		
40	47.9'	40	20.3'		
50	54.3'	50	20.3'		
60	6.0'	60	20.3'		

After test of well yield, water was:
 Clear and sand free
 Other, specify Cloudy
 If pumping discontinued, give reason:
 Pump intake set at (m/ft) 150
 Pumping rate (l/min / GPM) 4 gpm
 Duration of pumping 1 hrs + 0 min
 Final water level end of pumping (m/ft) 20.3'
 If flowing give rate (l/min / GPM) 2
 Recommended pump depth (m/ft) 190
 Recommended pump rate (l/min / GPM) 3 gpm
 Well production (l/min / GPM) 1" 2 gpm
 Disinfected? Yes No

Method of Construction

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Diamond	<input type="checkbox"/> Public	<input type="checkbox"/> Commercial	<input type="checkbox"/> Not used
<input checked="" type="checkbox"/> Rotary (Conventional)	<input type="checkbox"/> Jolting	<input checked="" type="checkbox"/> Domestic	<input type="checkbox"/> Municipal	<input type="checkbox"/> Dewatering
<input type="checkbox"/> Rotary (Reverse)	<input type="checkbox"/> Driving	<input type="checkbox"/> Livestock	<input type="checkbox"/> Test Hole	<input type="checkbox"/> Monitoring
<input type="checkbox"/> Boring	<input type="checkbox"/> Digging	<input type="checkbox"/> Irrigation	<input type="checkbox"/> Cooling & Air Conditioning	
<input type="checkbox"/> Air percussion		<input type="checkbox"/> Industrial		
<input type="checkbox"/> Other, specify		<input type="checkbox"/> Other, specify		

Construction Record - Casing

Inside Diameter (cm/in)	Open Hole OR Material (Galvanized, Fiberglass, Concrete, Plastic, Steel)	Wall Thickness (cm/in)	Depth (m/ft)		Status of Well
			From	To	
6"	Steel	48cm	0'	22'	<input checked="" type="checkbox"/> Water Supply <input type="checkbox"/> Replacement Well <input type="checkbox"/> Test Hole <input type="checkbox"/> Recharge Well <input type="checkbox"/> Dewatering Well <input type="checkbox"/> Observation and/or Monitoring Hole <input type="checkbox"/> Alleration (Constriction) <input type="checkbox"/> Abandoned, Insufficient Supply <input type="checkbox"/> Abandoned, Poor Water Quality <input type="checkbox"/> Abandoned, other, specify <input type="checkbox"/> Other, specify

Construction Record - Screen

Outside Diameter (cm/in)	Material (Plastic, Galvanized, Steel)	Slot No.	Depth (m/ft)		Status of Well
			From	To	
					<input type="checkbox"/> Abandoned, other, specify <input type="checkbox"/> Other, specify

Water Details

Water found at Depth (m/ft)	Kind of Water:	Kind of Water:	Depth (m/ft)	Diameter (cm/in)
	<input type="checkbox"/> Fresh <input checked="" type="checkbox"/> Untested	<input type="checkbox"/> Gas <input type="checkbox"/> Other, specify	From	To
?			0'	22'
				25.4cm

Well Contractor and Well Technician Information

Business Name of Well Contractor Thip Hain Sons Well Drilling Well Contractor's Licence No. 215 15 8
 Business Address (Street Number/Name) 256 Hall Shore Rd RR1 McDonald's Corners Municipality Or
 Province ON Postal Code K0G 1M0 Business E-mail Address wilfralltd@bellnet.ca
 Business Telephone No. (inc. area code) 613 278 2933 Name of Well Technician (Last Name, First Name) Hall Scott
 Well Technician's Licence No. 127 60 Signature of Technician and/or Contractor Scott Hall Date Submitted 2015/10/13

Map of Well Location

Please provide a map below following instructions on the back.

Bolingbrooke Road Cty Rd 36
3888
25' from Cabin

Well owner's information package delivered Yes No
 Date Package Delivered 2015/10/14
 Date Work Completed 2015/10/14

Ministry Use Only
 Audit No. 2217718
 Received NOV 10 2015