

**TOWNSHIP OF RIDEAU LAKES
SEWAGE SYSTEM COMPLETION CERTIFICATE**

(Ont. Building Code Act, S.O. 1992, c.23, as amended by S.O. 1997, c.24 and S.O. 1997, c.30, Schedule B')

Applicant: [REDACTED]			Permit #: <u>RL-89-99-5C</u>
Ward <u>S. CROSBY</u>	Lot <u>4-5</u>	Concession <u>8</u>	Assessment Roll #:
Inspection Details	Time <u>8:00</u> <input checked="" type="checkbox"/> a.m. <input type="checkbox"/> p.m.	Date: <u>24/NOV/99</u>	Representing Applicant: <u>RICHARD RAISSON</u> <i>Richard Raisson</i>

1. SEWAGE SYSTEM DETAILS:

- a) Septic tank/holding tank of working capacity of 3600 litres constructed of concrete plastic on site or prefabricated to serve 3 (no. of bedrooms or units).
Make of Prefabricated Tank PLANES LOWBOY
- b) Leaching bed with a total of 28 metres of 75 mm (millimetres) diameter distribution pipe of IPEX (type and product description) laid in 4 (4.8 m) runs and fed by GRAVITY (gravity, siphon, pump).
- c) Filter bed loading area 22 m²
- d) Other treatment units (Manufacturer/Model) _____
- e) Other details: _____

2. LOCATION:

- a) System components installed as shown on applications supporting the Permit
- b) System components installed as shown on the "As Constructed Plan"

3. Backfill Notification Received On:

Date: _____ Name of Notifier: _____

INSPECTED BY: <i>[Signature]</i>	ISSUED BY C.B.O. <i>[Signature]</i>	DATE: <u>24/NOV/99</u>
-------------------------------------	--	---------------------------

Information contained on this form is collected pursuant to the Ontario Building Code Act, 1992, as amended. The information may be released to members of the public upon request for a file search. Questions regarding the collection of this information should be directed to the Chief Building Official of the Township of Rideau Lakes.

4.8
6
8