

Site Basic Inspection Report



29 Main Street, E., Box 97
Westport, Ontario
K0G 1X0
613-273-5263 / Fax 613-273-7684
info@lakesidefireplaceandbbq.ca

Date: July 21/15
Customer Name: [Redacted]
Customer Address: 450 Brooks Point Rd.
Tel. #: [Redacted] Fax #: _____

Type of Dwelling: Owner Occupied Seasonal Residence Tenant Occupied

Chimney
Manufacturer Security Type H100 Size 6"
Approx. Length 6'
Height above roof exit 4'

Appliance
Manufacturer IHP (Iron Strike) Model S160A
Fireplace Furnace Woodstove Pellet

Clearance to Combustibles

Corner Installation	required	actual
Corners	<u>5 1/2"</u>	<u>9"</u>
Front	<u>/</u>	<u>/</u>

General Conditions
New Install

Wall Installation	required	actual
Back	<u>/</u>	<u>/</u>
Sides	<u>/</u>	<u>/</u>
Front	<u>/</u>	<u>/</u>

Flue Pipe
Clearance

Single Wall	Double Wall	required	actual
Straight <u>N/A</u>	Straight <u>6"/10"</u>	<u>8"</u>	<u>10"</u>
Corners <u>N/A</u>	Corners _____	<u>18"</u>	<u>18+</u>
Shield <u>N/A</u>	Manufacturer <u>N/A</u>		

Floor Pad
Type premanufactured pad - By the hearth

Remarks: In my opinion, I consider the installation of the chimney and/or wood-burning device at the above residence, meets the manufacturer's specifications or the requirements of the C.S.A. - B365.

Comments: _____

Signature [Signature]
Wett Certificate# 7717 Name Mark Partianert

