

A 026 904

- For use in the **Province of Ontario** only. This document is a permanent **legal** document. Please retain for future reference.
- **All Sections must** be completed in full to avoid delays in processing. Further instructions and explanations are available on the back of this form.
- Questions regarding completing this application can be directed to the Water Well Management Coordinator at 416-235-6203.
- **All metre measurements shall be reported to 1/10th of a metre.**
- Please print clearly in blue or black ink only.

										Ministry Use Only													
MUN						CON									LOT								

LEEDS				Kidew Lakes				2425		8	
RR#/Street Number/Name				City/Town/Village				Site/Compartment/Block/Tract etc.			
MOUNTAIN RD				WESTPORT							
GPS Reading		NAD	Zone	Easting	Northing	Unit Make/Model	Mode of Operation:				
		83	18	382760	4933557	Magellan Meridian	☐ Undifferentiated ☐ Differentiated, specify ☒ Averaged				

[illegible]

Hole Diameter		
Depth	Metres	Diameter
From	To	Centimetres
6.1	61.5	15.24

Water Record			
Water at	Found Metres	Kind of Water	
57	m	☒ Fresh	☐ Sulphur
☐ Gas		☐ Salty	☐ Minerals
☐ Other:			
	m	☐ Fresh	☐ Sulphur
☐ Gas		☐ Salty	☐ Minerals
☐ Other:			
	m	☐ Fresh	☐ Sulphur
☐ Gas		☐ Salty	☐ Minerals
☐ Other:			

After test of well yield, water was
☒ Clear and sediment free
☐ Other, specify _____

Chlorinated ☒ Yes ☐ No

Casing Record				
Inside diam centimetres	Material	Wall thickness centimetres	Depth	
			From	To
Casing				
1585	☒ Steel ☐ Fibreglass ☐ Plastic ☐ Concrete ☐ Galvanized	.188	0	6.1
	☐ Steel ☐ Fibreglass ☐ Plastic ☐ Concrete ☐ Galvanized			
	☐ Steel ☐ Fibreglass ☐ Plastic ☐ Concrete ☐ Galvanized			
Screen				
Outside diam	☐ Steel ☐ Fibreglass ☐ Plastic ☐ Concrete ☐ Galvanized	Slot No.		
No Casing or Screen				
	☒ Open hole		6.1	61.5

Test of Well Yield					
Pumping test method	Draw Down		Recovery		
	Time min	Water Level Metres	Time min	Water Level Metres	
Pump intake set at - (metres) 58	Static Level	7.2			
Pumping rate - (litres/min) 15	1	7.7	1	15.8	
Duration of pumping 1 hrs + 4 min	2	8.3	2	15.3	
Final water level end of pumping 16.6 metres	3	8.8	3	15.1	
Recommended pump type ☐ Shallow ☒ Deep	4	9.3	4	15.0	
Recommended pump depth. 58 metres	5	9.7	5	15.0	
Recommended pump rate. 20 (litres/min)	10	10.9	10	14.2	
If flowing give rate - (litres/min)	15	11.9	15	13.7	
	20	12.6	20	13.3	
	25	13.3	25	12.7	
If pumping discontinued, give reason.	30	13.8	30	12.3	
	40	14.9	40	11.4	
	50	15.7	50	11.0	
	60	16.6	60	10.3	

[illegible]

Method of Construction			
☐ Cable Tool	☒ Rotary (air)	☐ Diamond	☐ Digging
☐ Rotary (conventional)	☐ Air percussion	☐ Jetting	☐ Other
☐ Rotary (reverse)	☐ Boring	☐ Driving	

Water Use			
☒ Domestic	☐ Industrial	☐ Public Supply	☐ Other
☐ Stock	☐ Commercial	☐ Not used	
☐ Irrigation	☐ Municipal	☐ Cooling & air conditioning	

Final Status of Well			
☒ Water Supply	☐ Recharge well	☐ Unfinished	☐ Abandoned, (Other)
☐ Observation well	☐ Abandoned, insufficient supply	☐ Dewatering	
☐ Test Hole	☐ Abandoned, poor quality	☐ Replacement well	

Well Contractor/Technician Information	
Name of Well Contractor JR Thompson	Well Contractor's Licence No. 4905
Business Address (street name, number, city, etc.) 511 Wildlife Rd. Perth On.	
Name of Well Technician (last name, first name) Corell Stevenson	Well Technician's Licence No. 72419
Signature of Technician/Contractor x Stevenson Braden	Date Submitted (year, month, day) 2005 08 01

Location of Well

In diagram below show distances of well from road, lot line, and building.
Indicate north by arrow.

Diagram showing the location of a well relative to roads and distances:

- Mountain Rd
- Althorp Rd
- Distance to Westport: 320M
- Distance to maberly: 1.2 KM
- North arrow pointing towards the top right.

Audit No. Z 32893	Date Well Completed 2005 08 05
Was the well owner's information package delivered? ☐ Yes ☐ No	Date Delivered 2005 year 08 05 MM DD

Ministry Use Only			
Data Source		Contractor	
Date Received		Date of Inspection	
AUG 23 2005		4905	
Remarks		Well Record Number	